

NIXA FIRE PROTECTION DISTRICT

Adopted
09/20/11

Ordinance #
004-2011

Title
2006 IFC

Page 1 of 5

AN ORDINANCE REPEALING AND REPLACING IN ITS ENTIRETY ORDINANCE # 005-2006 OF THE NIXA FIRE PROTECTION DISTRICT FOR THE ESTABLISHMENT OF MINIMUM REGULATIONS GOVERNING THE INTERNATIONAL FIRE CODE 2006 EDITION.

WHEREAS, for the purpose of regulating and governing the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises in the district; and

WHEREAS, **Section 321.220(12)**, for the purpose of providing fire protection to property in the District, the district and, on its behalf, the board shall have the following powers, authority and privilege:

(12) To adopt and amend bylaws, fire protection and fire prevention ordinances, and any other rules and regulations not in conflict with the constitution and laws of this state, necessary for the carrying on of the business, objects and affairs of the board and of the district, and refer to the proper authorities for prosecution any infraction thereof detrimental to the district. Any person violating any such ordinance is hereby declared to be guilty of a misdemeanor, and upon conviction thereof, shall be punished as is provided by law therefore. The enactments of the fire district in delegating administrative authority to officials of the district may provide standards of action for the administrative officials, which standards are declared as industrial codes adopted by nationally organized and recognized trade bodies.

WHEREAS, The 2006 edition of the International Fire Code as published by the International Code Council (ICC) is the Fire Prevention Code of the Nixa Fire Protection District; for the control of buildings, structures as herein provided, and each and all of the regulations, provisions, penalties, conditions and terms of said Code are hereby referred to, adopted and made a part hereof as if fully set out in this Ordinance.

NOW, THEREFORE, BE IT ORDAINED BY THE BOARD OF DIRECTORS OF THE NIXA FIRE PROTECTION DISTRICT, as follows:

That Ordinance 005-2006 is repealed in its entirety and that the following is adopted as the new Fire Code of the Nixa Fire Protection District:

CODE ADOPTION

The 2006 edition of the International Fire Code as published by the International Code Council, IS THE Fire Prevention Code of the Nixa Fire Protection District and shall be

NIXA FIRE PROTECTION DISTRICT

Adopted
09/20/11

Ordinance #
004-2011

Title
2006 IFC

Page 2 of 5

executed by the City of Nixa Chief Building Inspector for the control of buildings and structures as herein provided, and each and all of the regulations, provisions, penalties, conditions and terms of said ICC International Fire Code are hereby referred to; adopted and made part hereof as is fully set out in this Ordinance, with additions, insertions, deletions and changes, if any prescribed by this ordinance.

AMENDMENTS

The 2006 edition of the International Fire Code for the Nixa Fire Protection District is amended to include:

I. Chapter 1, Administration:

A. Section 101.1, Authority, of the 2006 International Fire Code shall be amended to read as follows;

1. Insert the Nixa Fire Protection District

II. Chapter 5, Fire Service Features:

A. Section 503.1, Fire Lanes, of the 2006 International Fire Code shall be amended to read as follows;

1. The fire chief may designate fire lanes on private, and or, public property. Such area shall be designated by signs at each end of the lane which say "No Parking Fire Lane" with appropriate curb markings. Curb markings shall be red painted back ground with white painted letters six (6) inches in size. Fire lanes may be established on driveways and access roads required by the City on Nixa Planning and Zoning Department as recommended by the Fire Department applicable to the property in question, provided that fire lanes may not be established on property containing one or two family residential dwellings.
2. Upon notice by the fire chief of designation of a fire lane, it shall be the duty of the owner, occupant, or his agent, of the premises upon which the fire lane has been designated, to post proper signs and to maintain such signs and curb markings in good condition

B. Section 505.1, Address Numbers, of the 2006 International Fire Code shall be amended to read as follows;

NIXA FIRE PROTECTION DISTRICT

**Adopted
09/20/11**

**Ordinance #
004-2011**

**Title
2006 IFC**

Page 3 of 5

1. All such numbers shall be placed facing street, plainly visible from the street, shall be of a contrasting color to the background, shall be not less than four inches high, shall be in plain Arabic type, shall be made with a width equivalent to at least a half of an inch wide and shall not be more than 50 feet from the street, except as provided in subsection (2) of this section.
 2. If the number is more than 50 feet from the street, the numbers shall be a minimum of six inches in height, except in no event shall such number be more than 100 feet from the street.
 3. All businesses shall affix a street number to the rear of the business so as to be plainly visible from the rear access area. The size of the number posted shall be in accordance with the requirements set out in subsections (1) and (2) of this section.
- C. Section 506.1, Key Boxes, of the 2006 International Fire Code shall be amended to read as follows;
1. Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire-fighting purposes, the code official is authorized to require a key box to be installed in an accessible location. The key box shall be of an approved type and shall contain keys to gain access as required by the code official. The KNOX Key Box shall be ordered from www.knoxbox.com.
- D. Section 506.1.1, Locks, of the 2006 International Fire Code shall be amended to read as follows;
1. When a building within the Nixa Fire Protection District is protected by an automatic fire suppression or standpipe system.
 2. When a building is protected by an automatic alarm system and/or access to or within a building, or an area within that building, is unduly difficult because of secured openings, and where immediate access is necessary for life saving or firefighting purposes.
 3. When a property is protected by a locked fence or gate and where immediate access to the property is necessary for life saving or firefighting purposes.
 4. Any change of occupancy including renovations or remodel in a building meeting the requirements above.

NIXA FIRE PROTECTION DISTRICT

**Adopted
09/20/11**

**Ordinance #
004-2011**

**Title
2006 IFC**

Page 4 of 5

5. The KNOX Rapid Entry System shall be located;
 - a. Gated areas and secured areas around buildings and residential areas will be required to have a KNOX Key Switch or KNOX Pad Lock for emergency access.
 - b. Buildings shall place the box at or near the left of the recognized public entrance on the exterior of the structure approved by the Fire Marshal.
 - c. The lock box shall be located at a height of not less than four (4) feet and not more than six (6) feet above final grade.
 - d. An alternate location shall be approved by the Fire Marshal if construction features do not allow for placement near the entrance.
 - e. No steps, displays, signs or other fixtures, or structure protrusions shall be located under the box which would allow intruders to access the box without assistance.

6. The KNOX Box shall contain the keys and items of the following;
 - a. The main entrance door
 - b. Alarm room
 - c. Mechanical rooms
 - d. Sprinkler control rooms
 - e. Any other room specified during plan review
 - f. Fire alarm control panel
 - g. Special keys to pull-stations or other fire protection devices
 - h. Elevator keys
 - i. Alarm codes or alarm silencing procedure

The keys shall be labeled to be easily identified in the field

III. Chapter 9, Fire Protection Systems:

- A. Section 912.2, Fire Department Connections, of the 2006 International Fire Code is to be amended to read the following;
 1. With respect to hydrants, driveways, building and landscaping, fire department connections shall be so located that fire apparatus and hose

NIXA FIRE PROTECTION DISTRICT

Adopted
09/20/11

Ordinance #
004-2011

Title
2006 IFC

Page 5 of 5

connected to supply the system will not obstruct access to the buildings for other fire apparatus.

- a. Fire department connections shall be located a minimum of forty (40) feet or 1 and a half times the height of the building from the building whichever is greater on buildings with 3 or more stories or greater than 30' tall to minimize the potential for structural collapse onto fire department equipment and personnel. Fire department connections shall be located a maximum of thirty (30) feet from an accessible fire hydrant. Said hydrant shall be located on the same side of the fire department access road as the fire department connection. All fire department connections shall be painted red and labeled with signage reading "Fire Department Connection" in an approved method by the fire code official. Fire department connections not able to meet requirements based on location and access shall be approved by the fire code official.

INSPECTIONS AND ENFORCEMENT

The City of Nixa, Chief Building Inspector is responsible for inspections and shall have the authority to make inspections and enforce the ICC International Fire Code as adopted by the Nixa Fire Protection District.

Nothing in this ordinance or Fire Code hereby adopted shall be construed to affect any suit or proceeding in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired existing, under any act or ordinance hereby repealed: nor shall any just or legal right or remedy of any character be lost, impaired or affected by this Ordinance.

Adopted, by the Board of Directors of the Nixa Fire Protection District, this 20th day of September, 2011, and shall take full force and effect as of the 3rd day of October 2011.

Board President

Attest: Board Secretary